



- customer: Secco Sistemi SPA
via Terraglio, 195 - 31022 Preganziol (TV)
- test report number: N2779/22
- date of issue: 2022-08-31
- number of pages: 5 test report pages and 5⁽¹⁾ of attachments
- specimen description : Vertical pivot window with inward opening
- dimension: Area: 4,238 m² Openable joints: 8,212 m
- model ⁽¹⁾: OS2 75
- manufacturer ⁽¹⁾: Secco Sistemi SPA
via Terraglio, 195 - 31022 Preganziol (TV)
- CERT code: N2202/22
- date of sample arrival: 2022-08-25
- sampling performed by ⁽¹⁾: Secco Sistemi SPA
via Terraglio, 195 - 31022 Preganziol (TV)
- place of execution of the test: Secco Sistemi SPA
via Terraglio, 195 - 31022 Preganziol (TV)
- sample classification:

EN 12207:2016 - Windows and doors - Air permeability - Classification
EN 12208:1999 - Windows and doors - Watertightness - Classification
EN 12210:2016 - Windows and doors - Resistance to wind load - Classification

class 4
class 9A
class C4

- decision rule:

The classification of the sample is obtained by simply accepting the data obtained from the laboratory tests, excluding the associated measurement uncertainty values.

⁽¹⁾ data provided by customer

CIBIN ALESSANDRO
ORDINE ARCHITETTI P.C. PROV. VENEZIA
architetto Alessandro Cibi
31.08.2022 13:21:17 GMT+00:00

The results shown in the following report are relate only to item tested as received.

Reproduction of this document is allowed only in full copy. Partial reproduction or citation is permitted after t2i - trasferimento tecnologico e innovazione written authorization. The protocol authorization number must be reported in the lead of reproduction or citation. All the descriptive data of the sample reported in this test report and marked with (*), were provided by the customer. The laboratory declines all responsibility.